
MEMORANDUM

To: Mayor and City Council

From: Carl Carver, Stormwater Manager

Date: 9/12/2011

Subject: **Discussion of Contract for 4889 Village Creek Drive Culvert Lining**

ITEM DESCRIPTION

Discussion of Contract for 4889 Village Creek Drive Culvert Lining

NOTE: Bids are due September 8th. It is possible the low bid will be less than \$50,000 in which case this item will be removed from the agenda.

BACKGROUND

This project will consist of lining an existing 66-inch diameter corrugated metal pipe that conveys storm water under Village Creek Drive and replacing the downstream headwall. This project is necessary due to the development of a sinkhole at the edge of the road which could result in the loss of the road and the storm drain pipe. The sinkhole has been caused by the rusting out of the bottom of the existing pipe. A portion of the existing headwall has also collapsed and needs to be replaced. At this time there is still enough integrity in the pipe for it to be lined as opposed to complete excavation and replacement. By lining the pipe we will be able to keep the roadway open to traffic.

FUNDING

This project can be funded from \$120,000.00 capital reserve in the 2011 budget. A bid evaluation and a copy of the bids is attached for your review.

RECOMMENDED ACTION

Staff respectfully requests that Council:

- (1) Award the Village Creek Drive Project to _____
for the amount of \$ _____
- (2) Recommend a 10% contingency for unforeseen field conditions.